



Specified Fittings, LLC

164 West Smith Road • PO Box 28157 • Bellingham, WA 98228-0157 | Email: sales@specfit.com

Bellingham: 360-398-7700 | 360-398-7051 Fax
Stevensville: 406-777-3466 | 406-777-7181 Fax
Mexico (Toll Free): 800-429-1705 | 800-574-1075 Fax

October 26, 2010

Specified Fittings certifies to the following specifications for fittings for C900 PVC pipe:

INJECTION MOLDED FITTINGS FOR C-900 PIPE

All molded fittings for 4" through 8" C-900 pipe shall be one-piece injection molded or a combination made from a PVC compound meeting ASTM D1784. Fittings shall be Class 150 and conform to the requirements of DR 18. All fittings shall also meet the requirements of ANSI/AWWA standard C907-91. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477.

Fabricated FITTINGS FOR C900 pipe

All fittings for 4" through 12" C900 pipe shall be one-piece injection molded or fabricated from a PVC compound meeting ASTM D1784. Solvent weld- or gasket-end fittings are option of user. Solvent weld bells shall be compatible with C900 pipe. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477. Gaskets shall be locked-in style. All fittings shall be from NSF-61 materials for use in potable water systems.

If you have any other questions or need further information, please let us know.

Sincerely,
Brad Sukolsky
Technical and Quality Control Department
Specified Fittings