



Specified Fittings, LLC

164 West Smith Road • PO Box 28157 • Bellingham, WA 98228-0157

May 16, 2018

Re: Fabricated HDPE Fittings

To whom it may concern:

Specified Fittings certifies the referenced fittings are fabricated from materials conforming to:

ASTM F714 Standard specification for Polyethylene (PE) Plastic Pipe (SDR-PR) Based on Outside Diameter

ASTM D3350 Standard Specification for Polyethylene Plastic Pipe and Fittings Material
Material shall be PE4710.

ASTM D3035 Standard Specification for Polyethylene (PE) Plastic Pipe (SDR-PR). Based on Controlled Outside Diameter

With fittings conforming to the following as specified per Purchase Order

ASTM D3261 Standard Specification for Butt Heat Fusion PE Plastic Fittings for Polyethylene Plastic Pipe and Tubing

ASTM F2206 Standard Specification for Fabricated Fittings of Butt-Fused Polyethylene

AWWA C906 Polyethylene (PE) Pressure Pipe and Fittings, 4 In. Through 65 In. (100 mm Through 1,650 mm), for Waterworks

FM1613 Polyethylene (PE) Pipe and Fittings for Underground Fire Protection Service

All fittings are suitable for installation using the methods described in ASTM F2620.

If you have any questions or require more information, please contact me.

Sincerely,

Brad Sukolsky
Specified Fittings

