



November 18, 2019

Re: Integrally Restrained Joint PVC Fittings for C900 Pipe

To Whom it May Concern:

Specified Fittings certifies that integrally restrained joint Spec-Loc fittings provided for use with C900 PVC pipe conform to the following.

### **FABRICATED FITTINGS FOR C900 PIPE**

Fabricated fittings shall be made from PVC pipe made to AWWA C900 and DR of user's choice. PVC compound shall meet the requirements of cell class 12454 per ASTM D1784. Gasket bells shall conform to ASTM D3139 with gaskets conforming to F477. Gaskets shall be locked-in style incorporating Bulldog integral joint restraint system. All fittings shall be from NSF-61 materials for use in potable water systems. Configurations requiring external fiberglass reinforcement shall conform to quality requirements of ASTM D2563.

Thank you,

Brad Sukolsky  
Specified